

SECRET

25X1A Chief, [REDACTED]

25X1A Chief, [REDACTED] VIA TELEPOUCH

25X1A [REDACTED] R-2 Details

25X1A REF: [REDACTED] dated 11 September 1967

1. Following keyed to reference:

PARA 1.A. Concur.

PARA 1.B. For secure area wall construction acceptable choices include:

A. Concrete block.

B. Brick veneer over concrete block.

C. Brick cavity wall construction.

Only type reinforcing required is that normally included in such construction pursuant to [REDACTED] Engineer Guide Specifications and Design Criteria, for example duowall, shuregrip, etc. Such reinforcing should be provided every second course in a concrete block wall. Reinforcing used must be bonded as previously specified.

25X1C

PARA 1.C. Subject circuit breaker will be part of GFE switch-gear. Delete electrical - Para 2.

PARA 1.D. This being considered and will be decided after receipt A&E preliminary report.

PARA 1.E. Negative.

PARA 1.F. Negative.

PARA 1.G. If fuel same common tank acceptable.

PARA 1.H. Satisfactory.

PARA 1.I. This item covered in following dispatch.

PARA 1.J. Proposed location not acceptable due installation roof-top radome over that area. (Radome subject following dispatch.) Location near utility room not advisable due possibility exhaust fly ash being drawn into air conditioning intake. In present location combustion air may be taken in through roof-top vent. Vent must be protected in accordance with "Physical Security Standards Para B (2) (C)".

25X1A

22 SEP 1967

Excluded from automatic  
downgrading and  
declassification

RECD
C
DC 24K 7/26
EX 11/9/26/67
C/Acq
C/DC 24 Sept.
CES - 11/9/26
File 11/9/26
2936

20 September 1967

OC-E/ESB/AES, [REDACTED] jpt

25X1A

- 1 - OC-RMS
- 1 - OC-E
- 1 - OC-ED
- 1 - RESCD/OL
- 1 - AES File
- 1 - AES Chrono

RE&CD/OL

25X1A

CONSTRUCTION DIVISION  
BENTLEY

~~SECRET~~

[REDACTED] 25X1A

PARA 2.A. Concur.  
PARA 2.B. Concur.  
PARA 2.C. Only using agency furnished door will be vault door.  
All other doors contractor furnished. Concur  
remainder.  
PARA 2.D. Concur.  
PARA 2.E. Concur.  
PARA 2.F. Concur.  
PARA 2.G. Concur.  
PARA 2.H. Concur.  
PARA 2.I. Concur.  
PARA 2.J. Concur based on requirements of design.  
PARA 2.K. Concur.  
PARA 2.L. Concur

2. Added comment: Suggest canopies over all exterior doors.

[REDACTED] 25X1A

Distribution:

25X1A 3 - Chief, [REDACTED]

SECRET